

&gt;TAB.1&lt;

Miejscowosc: Nysa-Srodmiescie

Wariant: zlewnia pompowni P1

TABELA WYNIKOW DLA KANALOW

kan	wezel		Dlugosc	doplyw	przepl.	spad.	Srednica	Predk	wyp.	Rzedne dna	
	poc	kon								pocz	konc
-	-	-	m	dm3/s	dm3/s	%.	m	m/s	cm	mnpm	mnpm
39	49	26	160.0	0.0	25.6	2.5	0.40	0.42	19	185.89	185.49
22	27	26	39.0	0.0	22.5	2.6	0.40	0.41	18	186.24	186.14
21	26	25	70.0	0.0	48.1	2.0	0.50	0.45	26	185.39	185.25
20	25	24	95.0	1.5	49.6	2.0	0.50	0.46	27	185.25	185.06
19	24	23	90.0	1.5	51.1	2.0	0.50	0.46	27	185.06	184.88
18	23	9	95.0	0.0	51.1	2.0	0.50	0.46	27	184.88	184.69
17	22	21	150.0	1.5	1.5	5.0	0.20	0.26	5	186.54	185.79
16	21	19	14.0	0.0	4.5	5.0	0.20	0.36	9	185.79	185.72
16A	20	19	45.0	0.0	6.0	8.9	0.20	0.48	9	187.30	186.90
15	19	18	53.0	0.0	10.5	4.0	0.25	0.40	13	185.67	185.46
14	18	17	33.0	0.0	12.0	3.9	0.25	0.41	14	185.46	185.33
13	17	15	45.0	0.0	13.5	3.3	0.30	0.40	14	185.28	185.13
12	16	15	14.0	0.0	3.0	5.0	0.20	0.32	7	186.61	186.54
11	15	14	54.0	0.0	16.5	3.3	0.30	0.42	16	185.13	184.95
10	14	13	96.0	1.5	19.5	2.5	0.40	0.39	17	184.85	184.61
9	13	11	125.0	0.0	19.5	2.5	0.40	0.39	17	184.61	184.30
8A	12	11	60.0	1.5	1.5	5.0	0.20	0.26	5	186.39	186.09
8	11	10	122.0	1.5	22.5	2.5	0.40	0.41	18	184.30	183.99
7	10	9	133.0	0.0	22.5	2.5	0.40	0.41	18	183.99	183.66
6	9	8	138.0	0.0	73.6	1.5	0.60	0.46	33	183.46	183.25
5A	8	5	60.0	0.0	88.7	1.2	0.80	0.44	34	183.05	186.50
5	7	6	226.0	1.5	1.5	5.0	0.20	0.26	5	187.30	186.17
5B	6	5	30.0	0.0	4.5	5.0	0.20	0.36	9	186.17	186.02
5C	5	P1	6.0	0.0	93.2	1.7	0.80	0.50	32	185.42	185.41

TABELA WYNIKOW DLA WEZLOW

wezel	rzedne		doplyw	Zagl
	terenu	zwierc		
-	mnpm	mnpm	dm3/s	m
P1	188.50	185.73	0.0	3.09
5	188.50	185.74	0.0	3.08
6	188.27	186.26	3.0	2.10
7	188.90	187.35	0.0	1.60
8	188.25	183.39	15.0	5.20
9	188.00	183.79	0.0	4.54
10	188.50	184.17	0.0	4.51
11	188.15	184.48	0.0	3.85
12	187.99	186.44	0.0	1.60
13	188.15	184.78	0.0	3.54
14	188.15	185.02	1.5	3.30
15	188.25	185.29	0.0	3.12
16	188.21	186.68	3.0	1.60
17	188.00	185.42	1.5	2.72
18	188.10	185.60	1.5	2.64
19	188.50	185.80	0.0	2.83
20	188.90	187.39	6.0	1.60
21	188.50	185.88	3.0	2.71
22	188.14	186.59	0.0	1.60
23	187.70	185.15	0.0	2.82
24	187.62	185.33	0.0	2.56
25	187.74	185.52	0.0	2.49

obliczenia program "SIECW" v3.0

>TAB.1<				
26	187.95	185.65	0.0	2.56
27	187.84	186.42	22.5	1.60
49	187.49	186.08	25.6	1.60