

>TAB.1<

Miejscowosc: Nysa-Srodmiescie

Wariant: zlewnia pompowni P2

TABELA WYNIKOW DLA KANALOW

kan	wezel		Dlugosc	doplyw	przepl.	spad.	Srednica	Predk	wyp.	Rzedne dna	
	poc	kon								pocz	konc
-	-	-	m	dm3/s	dm3/s	%.	m	m/s	cm	mnpm	mnpm
38	48	47	150.0	0.8	1.5	5.0	0.20	0.26	5	187.39	186.64
37	47	46	210.0	1.5	3.0	5.0	0.20	0.32	7	186.64	185.59
37'	46	43	470.0	1.5	4.5	5.0	0.20	0.35	8	185.59	183.24
36	45	44	20.0	0.0	0.8	5.0	0.20	0.21	3	186.30	186.20
35	44	43	60.0	0.8	1.5	5.0	0.20	0.26	5	186.20	185.90
35'	43	42	54.0	0.0	6.0	5.0	0.20	0.38	10	183.24	182.97
33	42	40	8.0	0.0	6.0	5.0	0.20	0.38	10	182.97	182.93
34	41	40	180.0	0.8	6.0	5.0	0.20	0.38	10	185.90	185.00
33A	40	39	200.0	0.0	12.0	4.0	0.25	0.42	14	182.88	185.54
24	39	29	60.0	0.0	12.0	4.0	0.25	0.42	14	185.54	185.30
25	31	30	130.0	1.5	1.5	5.0	0.20	0.26	5	186.32	185.67
24B	30	29	22.0	0.0	10.5	4.0	0.25	0.40	13	185.62	185.53
24A	29	P2	10.0	0.0	22.5	2.5	0.40	0.41	18	185.15	185.13

TABELA WYNIKOW DLA WEZLOW

wezel	rzedne		doplyw	Zagl
	terenu	zwierc		
-	mnpm	mnpm	dm3/s	m
P2	187.65	185.31	0.0	2.52
29	187.60	185.33	0.0	2.45
30	187.55	185.75	9.0	1.93
31	187.92	186.37	0.0	1.60
39	187.14	185.68	0.0	1.60
40	187.00	183.02	0.0	4.12
41	187.50	186.00	5.3	1.60
42	187.10	183.07	0.0	4.13
43	188.20	183.34	0.0	4.96
44	188.45	186.25	0.0	2.25
45	187.90	186.33	0.8	1.60
46	188.48	185.67	0.0	2.89
47	189.50	186.71	0.0	2.86
48	188.99	187.44	0.8	1.60