

>TAB.1<

Miejscowosc: Nysa-Srodmiescie

Wariant: zlewnia pompowni P4

TABELA WYNIKOW DLA KANALOW

kan	wezel		Dlugosc	doplyw	przepl.	spad.	Srednica	Predk	wyp.	Rzedne dna	
	poc	kon								pocz	konc
-	-	-	m	dm3/s	dm3/s	%.	m	m/s	cm	mnpm	mnpm
46	56	54	120.0	0.8	10.5	4.0	0.25	0.40	13	186.49	186.01
47	55	54	50.0	0.4	12.0	4.0	0.25	0.42	14	186.22	186.02
45	54	52	155.0	0.0	22.6	2.5	0.40	0.41	18	185.86	185.47
44	53	52	15.0	0.0	1.5	4.7	0.20	0.25	5	186.25	186.18
43	52	50'	15.0	0.0	24.1	2.0	0.40	0.38	20	185.47	185.44
41	51	50'	36.0	0.0	1.5	5.0	0.20	0.26	5	186.13	185.95
42	50'	P4	5.0	0.0	25.6	4.0	0.40	0.51	17	185.44	185.42

TABELA WYNIKOW DLA WEZLOW

wezel	rzedne		doplyw	Zagl
	terenu	zwierc		
-	mnpm	mnpm	dm3/s	m
P4	187.80	185.59	0.0	2.38
51	187.73	186.18	1.5	1.60
52	187.85	185.67	0.0	2.38
53	187.85	186.30	1.5	1.60
54	188.10	186.04	0.0	2.24
55	187.82	186.36	11.7	1.60
56	188.09	186.62	9.8	1.60
50'	187.80	185.61	0.0	2.36